

PROFORMA REGARDING SAFE DRINKING WATER SANATARY CONDITION
CERTIFICATE


NO. 357.....

DATED: 17.04.2026

It is certified that an inspection team headed by Prashant Khullar Sub Engineer (Name of officers with designation) from Municipal Corporation Ambikapur (Name of Department /Officers) inspected the **HOLLY CROSS CONVEVT SENIOR SECONDARY SCHOOL AMBIKAPUR** (Name & Address of the School) on.. 13.04.2026 and found that the **HOLLY CROSS CONVEVT SENIOR SECONDARY SCHOOL AMBIKAPUR** has safe drinking water facility for the student and member of staff of institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed the central/state/U.T. Govt.

The above valid for a period of **01 Years** from the date of issue.

Signature with seal


~~Assistant Engineer~~
Municipal Corporation

Name

: Prashant Khullar

Designation

: Assistant Engineer

To,

Principal

Holly Cross Convent Senior Seondry School

Ambikapur (C.G.) 497001

(Name & Address of the insitution)



District Water Testing Laboratory
Public Health Engineering Department, Division Ambikapur
Shree Mahaveer Ward No. 20 Bangali Chowk,, Ambikapur, Distt. Surguja(C.G.)
Email:-eeamb-phe-cg@nic.in

Test Report (Drinking Water)

Report No. :- 481	Discipline:- Chemical Testing	Group:- Drinking Water	TC -16638	Temperature:- 25.6°C
			Lab ID : T- 11304	Humidity:- 60%
Customer Name & Address :- Holy Cross Convent Senior Sec. School, Ambikapur Distt. :- Surguja (C.G.)	Customer Letter No./Date	-	Sampled by	School staff
	Sample Collection Date	09/04/2026	Sample Condition	Good, 1 litre at 4 °C
	DL Receipt No.	04/2026-477	DL Receipt Date	09/04/2026
	Date of Analysis Started	09/04/2026	Date of Analysis Completed	13/04/2026

Sample Details

S.N.	Sample I.D.	District / Block	City / Village	Habitation	Location/Source ID/GPS Identification
1.	DL/PHED/AMB-1837	Surguja/Ambikapur	Ambikapur	Ambikapur	Holy Cross Convent Senior Sec. School, Ambikapur
2.					
3.					
4.					
5.					


Details of parameters their Test method units and specification as per IS/APHA

S. N.	Parameters	Test method IS:3025/APHA 23rd ed. Method	Unit	As per IS-10500-2012 Drinking Water		Result of S.No.				
				Acceptabl e Limit	Permissibl e Limit	01	02	03	04	05
(1)	(2)	(3)	(4)	(5)	(6)	-	-	-	-	-
1	Turbidity	APHA24th edition-2130-Turbidity Method B	NTU	1	5	0.31				
2	Colour	APHA24th edition-2120-Colour Method B(Platinum Cobalt Visual Comparison)	HU	5	15	1.00				
3	Odour	IS:3025(Part 5)		Agree	Agree	Agree				
4	Taste	IS:3025(Part 8)		Agree	Agree	Agree				
5	PH @25°	APHA24th edition-4500-H+Method B	PH scale	6.5-8.5	6.5-8.5	7.57				
6	Alkalinity as CaCO ₃	APHA24th edition-2320-Alkalinity Method B(Titration Method)	mg/l.	200	600	107.69				
7	TDS	APHA24th edition-2540-TDS Method C(Dried at 180 Degree Celsius)	mg/l.	500	2000	200.00				
8	Chloride as Cl	APHA24th edition-4500-Cl Method B(Argentometric Method)	mg/l.	250	1000	44.88				
9	Total Hardness as Ca CO ₃	APHA24th edition-2340-Hardness Method C(EDTA method)	mg/l.	200	600	92.73				
10	Calcium as Ca ⁺⁺	APHA24th edition-3500-Ca method B(EDTA Method)	mg/l.	75	200	26.61				
11	Magnesium as Mg ⁺⁺	APHA24th edition-3500-Mg Method B(By CalHULATION)	mg/l.	30	100	6.36				

Remark:-

1. The report should not be produced partly or full without approval signatory authority of legal purpose.
2. The results refer only to tested samples and parameters as received from the costumer.
3. Samples will be stored for a period of 10 days from date of issue of report.
4. The laboratory is responsible for all this informations given in this report.

**** End Of Report****


(K.K. Sinha) Manager
 Report Reviewed & Authorised by
 DWTL PHED Ambikapur Surguja (C.G.)